

# Water Quality Association

08/01/2013



## NSF/ANSI-61 International Standard for Drinking Water Additives

### NSF/ANSI-61 Drinking Water System Components - Health Effects

This Standard establishes minimum health effects requirements for the chemical contaminants and impurities that are indirectly imparted to drinking water from products, components, and materials used in drinking water systems. This Standard does not establish performance, taste and odor, or microbial growth support requirements for drinking water systems products, components, or materials.

Drinking Water Treatment Products certified to NSF/ANSI 61 have not been tested or evaluated for contaminant reduction performance. Contaminant reduction testing and certification claims shall be evaluated via the industry's residential drinking water treatment standards.

#### Gemite Products Inc.

1787 Drew Road  
Mississauga, ON LS51J5

#### Product Type: Barrier Materials

<i>Brand Name</i>	<i>Model</i>	<i>Water Contact Temp</i>	<i>Water Contact Material</i>	<i>Size</i>
	Cem-Kote CW Plus (a) (b) (c) (d) (e) <sup>1 2 3 4 5 6</sup>	CLD 23C	Crystalline Waterproofing	Max SA/V 17 sq cm / L
	Cem-Kote Flex ST (a) (b) <sup>1 2 6</sup>	CLD 23C	Polymer Modified Mortar Waterproofing	Max SA/V 17 sq cm / L

<sup>1</sup> : (a) - Coating for use with tanks greater than or equal to 10,000 gallons

<sup>2</sup> : (b) - Minimum Cure Time = 3 days, Maximum Thickness = 80 mils, Apply in accordance with manufactures use instructions.


- 3: (c) - Mix 50 lbs (22.7 kg) of the product with approximately 1.2-1.3 USG (4.6-5.0 L)
- 4: (d) - Gradually add the dry material into the water and mix until a smooth and lump free mix is obtained. Do not over mix. Adjust the water for desired consistency.
- 5: (e) - The product may be brushed, sprayed, or dry distributed.
- 6: This product is certified at a maximum surface area to volume ratio not to exceed 17 sq cm/L.
- 



## Disclaimer:

The information in the Water Quality Association product listings directory is made available by WQA for users of this website and shows currently certified products. Every effort has been made to verify the accuracy of all listings in this directory. The association can assume no liability for errors or omissions.

---

Water Quality Association:  Back  
Thu, Aug 1, 2013

Copyright 2013 by the Water Quality Association – All rights reserved.  
Water Quality Association  
International Headquarters & Laboratory  
4151 Naperville Road  
Lisle, IL 60532-3696  
USA  
630 505 0160, Fax 630 505 9637  
[info@wqa.org](mailto:info@wqa.org), [www.wqa.org](http://www.wqa.org)

[Disclaimers](#)